



Jim Doyle, Governor
Mary P. Burke, Secretary

July 11, 2007

ALL AMERICAN HOMES INC
PERRY LEHRMAN
309 S 13TH ST
DECATUR IN 46733-0968

ALL AMERICAN HOMES, INC.
JOHN MEYER
1551 15TH AVE S E
PO BOX 219
DYERSVILLE IA 52040-0219

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: ALL AMERICAN HOMES, INC.
Product Name: GEORGETOWN SERIES
Model Number(s): G 46X60 3 2 STD AND G 46X60 3 2 B STD
Product File No: 20070335

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2014.

This approval supersedes the approval issued on December 18, 2003, under product file number 20030518.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030518.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 38 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov